



**ARIZONA DEPARTMENT OF ENVIRONMENTAL QUALITY
 CERTIFICATE OF APPROVAL TO CONSTRUCT
 DRINKING WATER WELL FACILITIES**

ADEQ File No: 20230272	LTF No: 99523
System Name: Trujillo Trails Dwid	System Number: 12-040
Project Owner: Trujillo Trails Dwid	
Address: Po Box 5111, Tubac City , AZ 85646	
Project Location: Tubac	County : Santa Cruz
Description: TTDWID WATER IMPROVEMENTS 2022. ATC PERMIT FOR THE INSTALLATION OF WELL (#55-574654), 4,000 GAL STEEL STORAGE TANK, 2 X 30 GPM/5 HP GOULD DM-30-170-2VS BOOSTER PUMP, 6,097 LF OF 4-INCH PVC TRANSMISSION LINE AND RELATED APPURTENANCES FOR TRUJILLO TRAIL DWID. WELL IS EQUIPPED WITH 25 GPM SUBMERSIBLE PUMP SET AT 230 FT BGS. PWS GRADE D1.	

Approval to construct the above-described facilities as represented in the approved documents on file with the Arizona Department of Environmental Quality is hereby given subject to provisions 1 through 8 continued on page 2 through 3

1. This project must be constructed in accordance with all applicable laws, including Title 49, Chapter 2, Article 9 of the Arizona Revised Statutes and Title 18, Chapter 5, Article 5 of the Arizona Administrative Code.
2. Upon completion of construction, the engineer shall fill out the Engineer's Certificate of Completion and forward it to the Central Regional office located in Phoenix. If all requirements have been completed, that unit will issue a Certificate of Approval of Construction. R18-5-507(B), Ariz. Admin.Code. At the project owner's request, the Department **may** conduct the final inspection required pursuant to R18-5-507(B); such a request must be made in writing in accordance with the time requirements of R18-5-507(C), Ariz. Admin. Code.
3. This certificate will be void if construction has not started within one year after the Certificate of Approval to Construct is issued, there is a halt in construction of more than one year, or construction is not completed within three years of the approval date. Upon receipt of a written request for an extension of time, the Department may grant an extension of time; an extension of time must be in writing. R18-5-505(E), Ariz. Admin. Code.
4. Operation of a newly constructed facility shall not begin until a Certificate of Approval of Construction has been issued by the Department. R18-5-507(A), Ariz. Admin. Code.

Reviewed by : JM23

DocuSigned by:
Jasmina Markovski 8/10/2023
 By: BECD4C0BB9174E9
 Jasmina Markovski , P.E. Date
 Water Quality Division

cc: File No : 20230272
 Regional Office: Central
 Owner: Trujillo Trails Dwid
 County Health Department: Santa Cruz
 Engineer: Teamconverse Llc
 Planning and Zoning/Az Corp. Commission
 Engineering Review Database - Etr022

**APPROVAL TO CONSTRUCT
POTABLE WELL, STORAGE TANK, BOOSTER PUMPS, TRANSMISSION LINE
ADEQ FILE NO: 20230272
PAGE 2 OF 2: PROVISIONS CONTINUED**

5. Approval of Construction (AOC) will not be issued until data is obtained and verified for Pressure and Leakage Tests and Disinfection Sampling of constructed well and water lines. Per Bulletin No. 10, Chapter 2.E.20, Disinfection Requirements; requires that...”Every new, modified or reconditioned groundwater source shall be disinfected after placement of final pump equipment. Information on disinfection procedures can be obtained from Engineering Bulletin No. 8, “Disinfection of Water Systems”.

It is recommended that the Engineer’s Certificate of Completion (ECC) Data Required Sheet be completed in full, showing actual pressures and sampling data. Data required with ECC sheet can be found under heading - Safe Drinking Water and subheading - Technical Engineering/Plan Reviews

<http://legacy.azdeq.gov/environ/water/dw/download/data.pdf>

6. This approval to construct does not include approval for the connection of the well to the water system. Approval to connect the well will not be given until the well development information and water quality data has been submitted. ***The required data includes copies of ADWR approval of change of use for the well, well drillers report, log of well, well completion report, pump test data and complete water quality information.***
7. Emergency Disinfection – Satisfactory means for emergency disinfection shall be constructed as a part of all water sources. It is recommended that the system have a piping and electrical connection for chlorination equipment to be used when there is a need for emergency disinfection. See Bulletin No. 10, Chapter 2.A.3.
8. The Arizona Department of Environmental Quality’s review of this application was subject to the requirements of the licensing time frames (“LTF”) statute under Arizona Revised Statutes (“A.R.S.”) § 41-1072 through § 41-1079 and the LTF rules under Arizona Administrative Code (“A.A.C.”) R18-1-501 through R18-1-525. This Notice is being issued within the overall time frame for your application.

ADEQ hereby approves your application for Approve to Construct Drinking Water Facilities under A.R.S. § 49-351. Your copy is enclosed.

This decision is an appealable agency action under A.R.S. § 41-1092. You have a right to request a hearing and file an appeal under A.R.S. § 41-1092.03(B). You must file a written Request for Hearing or Notice of Appeal within **30 days** of your receipt of this Notice. A Request for Hearing or Notice of Appeal is filed when it is received by ADEQ’s Hearing Administrator as follows:

Office of Administrative Counsel
Arizona Department of Environmental Quality
1110 W. Washington Street
Phoenix, AZ 85007

The Request for Hearing or Notice of Appeal shall identify the party, the party's address, the agency and the action being appealed and shall contain a concise statement of the reasons for the appeal. Upon proper filing of a Request for Hearing or Notice of Appeal, ADEQ will serve a Notice of Hearing on all parties to the appeal. If you file a timely Request for Hearing or Notice of Appeal you have a right to request an informal settlement conference with ADEQ under A.R.S. § 41-1092.06. This request must be made in writing no later than **20 days** before a scheduled hearing and must be filed with the Hearing Administrator at the above address.

Please contact Jasmina Markovski at (602) 771- 4827 or Markovski.jasmina@azdeq.gov if you have questions regarding this Notice or the Certificate of Approved to Construct.